

DATE – 09/05/2023

**PROJECT: PROPOSED REDEVELOPMENT OF OUTFIELD AT WANKHEDE STADIUM,  
CHURCHGATE, MUMBAI.**

**SUBJECT: CLARIFICATIONS BASED ON THE PRE BID MEETING HELD AT MCA OFFICE  
DATED 08/05/2023 AT 3.00 P.M.**

Below mentioned are the final decisions and clarifications taken during a the pre-bid meeting held for the above-mentioned project.

1. It was decided to consider application of selective herbicide to eliminate the contaminants prior to Korowing.
2. Sprigging / dibbling should be done and care should be taken that the sprigs should be devoid of soil as it is sand based outfield.
3. Considering the onset of monsoon, the contractor should stock and store total quantity of all the materials required for the execution of the project, not limited only to sand within 10 days of the start of the project. The sand should be of specific quality as required by MCA and it was decided to give reference of the supplier from which MCA regularly procures the sand for the uniformity of the material. (Gore & Company – 09423872792, 07499875946). The bidder should get the sample of the sand approved from MCA before its procurement.
4. The makes of herbicides, fertilizers and other products needs to be provided by the bidder during the submission of the tender along with the application methodology. The same should be approved by the client before the start of the work at site.
5. In Volume III (BOQ) of the tender document, the unit of measurement for the item specification of providing the sand should be **Cmt** instead of **Smt**.

Based on the above discussion points, hereby attached is the revised BOQ which the bidder has to consider for their working and submission.